



1222 Moonshine Rd,
RD1, Porirua 5381
Private Bag 50 908
Porirua 5240
New Zealand
P: +64 4 237 1170
branz.co.nz

Ref: BRANZ Appraisal 524 Cavibat Cavity Battens

7/10/2021

Cavity Batten Systems Ltd
7/23 Tukorako Drive
Mt Maunganui 3116

Dear Graeme

BRANZ has been notified by Cavity Battens Systems Ltd that there has been a supply issue for their 18 mm thick Cavibat Cavity Battens.

They have proposed to substitute the 18 mm thick batten with two 10 mm thick battens to create a 20 mm cavity. The proposed 10 mm thick batten is the same 10 mm thick extruded polypropylene that is currently used as part of the Cavibat R Cavity Batten.

BRANZ has reviewed the information provided and has approved the use of two 10 mm thick polypropylene battens to create a 20 mm cavity to substitute the 18 mm thick battens while Cavity Batten Systems Ltd are having supply issues in 2021. The affected stock will have a sticker on them stating the installation method.

Yours faithfully

A blue ink signature of Peony Mudgway.

Peony Mudgway
Building Technologist – Assurance Services
7/10/2021

A blue ink signature of Darrel Hannon.

Darrel Hannon
Technical Manager
7/10/2021